

### Validation of icing and wind power forecasts at cold climate sites

Øyvind Byrkjedal, Henrik van der Velde, Bjørn Egil K. Nygaard oyvind.byrkjedal@vindteknikk.no

Winterwind 2015, Piteå, February 3-4 2015



Toppforskningsinititativet



### **Power forecasts**

- WRF simulations at 6km x 6km resolution
- 4 times daily
- GFS 48 hour forecasts

# Forecasting of icing

The aim is to know when icing will occur:

- Power trading
- Blade heating systems:
  - Start the heating before icing starts
  - Avoid unnecessary stops during heating
- Risks of ice throw / ice fall
  - Planning of maintainance
  - Public safety
- Monitoring of exposed power lines
  - Avoid damages







Ålvikfjellet, January 2014, foto: Ole Gustav Berg, Statnett

### Meteorological icing vs instrumental icing



### Icing on a regional scale - Icing rate





# Validation of icing forecasts

### Validation of large ice loads



# Validation of icing

- Identification of icing from SCADA data:
  - Davis et al. (2014)
  - P10 treshold curve
  - Time constraints
  - Temperature constraints





## Validation of instrumental icing

• The periods with observed instrumental icing compared to modelled periods with instrumental icing.



	Site 1	Site 2	Site 3
Ratio of time when ice is detected	21 %	13 %	10 %
False alarm ratio	2.4 %	2.9 %	5.6 %
Probability of detection	73 %	68 %	81 %



### Validation of meteorological icing - Timing

 60 % of the observed icing episodes starts when the model indicates meteorological icing

Timing challenge:

- In 25 % of the cases the model
  forecasted the icing too late
- Time shift of the results gives improved timing of icing for this site





# **Energy forecasts**

### Forecasting of power losses



### Forecasting of power production

• **Bias and mean absolute error** (MAE) in the forecasts are **reduced** when we include production losses due to icing



14

### Summary

- Gained experiences from operational forecasting of icing
- Validation of instrumental icing:
  - Able to predict the large buildup of icing that resulted in power line damages in 2013-2014
  - Probability of detection: 68-81%
  - False alarm ratio: 2-5 %
  - Validation of meterological icing:
    - 60 % of the observed icing episodes starts when the model indicates meteorological icing
    - Validation of power forecasts:
      - General improvement of the power forecasts when the icing is included.



### Thank you for your attention!







Toppforskningsinititativet



### Icing conditions

- Temperatures below freezing
- cloud or fog containing small water droplets
- Something to freeze to

in-cloud icing



### Calculation of in-cloud icing

 Icing intensity calculated according to ISO 12494:

 $\frac{dM}{dt} = \alpha_1 \alpha_2 \alpha_3 \cdot w \cdot A \cdot V$ 

 $\alpha_1$ - collision efficiency,  $\alpha_1 = f(V,d,D)$   $\alpha_2$ - sticking efficiency,  $\alpha_2 \approx 1$   $\alpha_3$ - accretion efficiency,  $\alpha_3 = f(V,d,w,T,e,D,\alpha_1)$ w - cloud liquid water content A - collision area, perpendicular to flow V - Wind speed





### **Observation data**

- Data from one wind farm:
  - 10 minute frequency
  - power, nacelle wind speeds, temperature, turbine alarms
- Identification of icing from power data:
  - Temperature treshold: T<+2 °C</li>
  - Power treshold: P < P<sub>low</sub>
- Definition of icing periods:
  - Icing identified for 3 or more turbines
  - Duration of minimum 12 hrs
  - Aggregated to 20% power loss or more





### Forecasting of power



- Reduced number of cases with overprediction of power production in the forcast with icing
- Higher number of cases with error less than 12.5 % in the forcast with icing
- Higher number of cases with underprediction of the power production in the forecast with icing



### Power loss during periods with instrumental icing

