

Wind power forecast in Germany

General approach, practical applications and options for considering effects of wind turbine icing

Michael Durstewitz

ISET

Germany

mdurstewitz@iset.uni-kassel.de

Contents

Introduction


Wind energy development in Germany

Challenges of grid integration


Forecasting of Wind power

Influences of icing situations to forecast quality


Wind power development in Germany



Electricity production by wind '99 – '07



Introduction



Wind Energy in Germany

Installations

22,100 MW

19,250 WT

as of 12 / 2007

Energy Production

26.4 TWh in 2005

30.3 TWh in 2006


38.5 TWh in 2007

Wind power installations and TSO regions




TSO mission

- balancing of power generation and demand
 - maintain grid stability voltage, frequency
 - provide reserve power
- (UCTE: 3000 MW primary control reserve)



Situation today



- Hundreds of wind farms and single turbines
- Fluctuating power generation
- Non-dispatchable generators
- Privileged production of RE
- Purchase commitment by utilities


→ consequences for stable and reliable grid operation

Information about
actual state of wind power feed-in
+ short & medium term forecast
is essential




Foto: NEG Micon

Situation tomorrow → results of DENA study



No conventional generation is running
=> Grid management (frequency, voltage control, ...) needed

Prediction Methods



Models and Tools for TSOs

Step 1:

Online model calculates from few measured windfarms the current power for all plants

Step 2:

Prediction model calculates on the basis of the current power of all plants and the weather forecast the future wind power feed-in

Accuracy in the statistical average


> 94 % for the D+1 forecast

> 96 % for the 4 hours forecast



Wind Power Management System


Prediction Methods



Sub-division of the control zones
in small areas (like FEM)

8585 areas (on- and offshore)

Online calculation methods



Calculation of current power output of each grid square by evaluation of all representative power signals


$$P_{sum} = \sum_i P_i$$

*considered parameters:
distance
roughness
control systems*

$$P_i = P_{cap i} k_i \sum_j s_j * A_{tj} * P_j$$

Prediction Methods


I/Ro 11-2003



**Calculation of expected power output
of each grid square
by evaluation
of all representative
wind farm power output
predictions**

**using NWP models
and
Artificial Neural Networks**

Prediction Methods




Artificial Neural Networks

$$\hat{P}(t) = g \left[\sum_{j=1}^m A_j g \left(\sum_{k=1}^n w_{jk} x_k(t) \right) \right]$$

Support Vector Machines


$$f(w_t) = \text{sign} \left[\sum_{\text{support vectors}} P_i \alpha_i K(w_i, w_t) - b \right]$$

Prediction Methods




Wind generation – online, day-ahead forecast

Prediction Methods




Wind generation – online, 4 hour forecast

Prediction Methods



Wind generation – online, 2 hour forecast

Prediction Methods





Short-term forecasts with associated confidence areas

Integration of large quantities of wind power into the energy supply



Dispatch
centre TSO



Measurement from 25.12.2004 00:00
to 25.12.2004 12:15
DWD forecast of 24.12.2004 07:00

Total instantaneous power output: 7994 MW
Instantaneous capacity factor: 0,00 %

#	St...	On...	Name	Capacity	ICF	#	State	On...	Name	Capacity	ICF
1		<input checked="" type="checkbox"/>	Nordenham	13.5 MW	83.5 %	2		<input checked="" type="checkbox"/>	Niederlangen	93.0 MW	30.5 %
3		<input checked="" type="checkbox"/>	Holtriem	52.5 MW	70.4 %	4		<input checked="" type="checkbox"/>	Manslagt	29.1 MW	78.0 %
5		<input checked="" type="checkbox"/>	Freiburg	40.6 MW	75.8 %	6		<input checked="" type="checkbox"/>	Krempl	80.8 MW	58.4 %
7		<input checked="" type="checkbox"/>	Travemuende	7.9 MW	45.9 %	8		<input checked="" type="checkbox"/>	Lindewitt	34.0 MW	93.2 %
9		<input checked="" type="checkbox"/>	Niebuell	24.21 MW	80.7 %	10		<input checked="" type="checkbox"/>	Ulrichstein	10.3 MW	33.8 %
11		<input checked="" type="checkbox"/>	Gettorf	13.5 MW	116.5 %	12		<input checked="" type="checkbox"/>	Benhausen	33.275 MW	22.2 %
13		<input checked="" type="checkbox"/>	Daseburg	32.0 MW	8.2 %	14		<input checked="" type="checkbox"/>	Schwickeldt	31.3 MW	48.5 %
15		<input checked="" type="checkbox"/>	Bleckenstedt	27.9 MW	61.4 %	16		<input checked="" type="checkbox"/>	Wedehorn	33.9 MW	59.3 %
17		<input checked="" type="checkbox"/>	Stadof	38.75 MW	65.6 %	18		<input checked="" type="checkbox"/>	Bueren	46.25 MW	28.5 %
19		<input checked="" type="checkbox"/>	Emern	24.0 MW	76.1 %	20		<input checked="" type="checkbox"/>	Pennigsehl	51.0 MW	38.8 %
21		<input checked="" type="checkbox"/>	Katensen	31.5 MW	13.2 %	22		<input checked="" type="checkbox"/>	Gestorf	16.0 MW	54.6 %
23		<input checked="" type="checkbox"/>	Bentstreek	18.0 MW	80.2 %	24		<input checked="" type="checkbox"/>	Damsum	26.4 MW	64.4 %
25		<input checked="" type="checkbox"/>	Ihlow	49.8 MW	78.2 %	26		<input checked="" type="checkbox"/>	Lorup	37.8 MW	74.3 %
27		<input checked="" type="checkbox"/>	Oersdorf	46.7 MW	56.2 %	28		<input checked="" type="checkbox"/>	Tewel	35.2 MW	31.4 %
29		<input checked="" type="checkbox"/>	Rhede	77.4 MW	64.4 %	30		<input checked="" type="checkbox"/>	Wybelsum	37.5 MW	68.7 %
31		<input checked="" type="checkbox"/>	Wilhelmshav...	8.0 MW	78.7 %	32	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	Wulfenau	39.6 MW	0.0 %

Wind Farm Control, Prediction Systems


AI-based Prediction System WPMS

E.ON Netz,
Vattenfall Europe Transmission,
RWE Transportnetz Strom,
EnBW Transportnetze


Verbund Austria
TERNA Italien
Egypt, Zafarana
UK, National Grid

Wind FarmCluster Management WCMS

E.ON Netz
Vattenfall Europe Transmission
Red Electrica Espana
Redes Energeticas Nacionais



Forecast errors - statistics



Prediction error for TSO control zone

Mean errors (2006)

$< 6.0\% \text{ RMS}$ (24h forecast)

$< 3.5\% \text{ RMS}$ (4h forecast)

Forecast error reasons:

- weather forecasts
storm: ATA \neq ETA
- different trajectory of predicted storm
- other systematic errors
- Turbine response is utterly at variance with standard behaviours

? → icing

Wind & ice




Foto: VTT


Reduced aerodynamic efficiency

Faulty sensor signals

M. Durstewitz, Vinterwind 2008, Åsele, SE



Forecast errors caused by icing ????



Task:

Analyse forecast quality
with measured results

Selected sites:
Mountainous regions
Elev. 300 – 700 m asl

Example:

WP Ulrichstein/Vogelsberg
sev. types / ~ 11 MW_{tot}



Elevation ~600 m asl

Low mountain range

Several icing reports


WP Ulrichstein / Temperatur profile (2004 - 2008 JAN, FEB, DEC)

Frequency distribution of ambient temperature




Span of T and avg temp. by months

Distribution of observed forecast errors vs. temperature



Power output vs. wind speed (WP Ulrichstein)



Conclusions / next steps

- *WPMS is a powerful tool for integrating wind power*
- *Reliability of results has to be checked for low temperatures*

Next steps:

- *Analysis of data from other sites*
- *Inclusion of further meteorological parameter*
- *Search for typical footprints*
- *Integration into ANN training procedure*
- *Verification of results*
- ...
- *Implementation into update WPMS*