

# OPERATING EXPERIENCES WITH ANTI-ICING SYSTEMS IN NORDEX TURBINES




Winterwind 2013,  
Dr. A. Löwe



- **Introduction to Nordex**
- **Nordex Anti-Icing Option**
  - System features
  - Projects in the field
- **Performance analysis of winter season 2011/12**
  - Webcam observations
  - Icing simulations
  - Comparison of power yield





**800 MW** of cold climate turbines in operation

**120 MW** of turbines with Anti-Icing systems in the field

- **Continuous monitoring** of icing conditions
- The system operates **while the turbine is running**
- Heating of the **aerodynamically relevant blade surface**
- Reliable and lightweight **electrical resistance heaters**
- Based on pilot system by **VTT**



VTT Technical Research Centre of Finland



## 2010:

4 WTGs (N100/2500 R100 CCV) in Jokkmokksliden

3 pilot Anti-Icing Systems

1 reference turbine

## 2011:

+ 14 WTGs in Jokkmokksliden/Storliden

+ 2 WTGs in Vårdkasen


## 2012:

+ 30 WTGs in Blaiken


## 2013:


+ 30 WTGs in Blaiken

+ 1 WTG in Finland









**It works!**



- Third party evaluation by Kjeller Vindteknikk
  - Determination of theoretical **icing times by simulation**
  - Determination of **theoretical production**  $P_{\text{theor}}$  from individually determined power curve of each turbine
  - Determination of **production losses**  $P_{\text{loss}}$  by  $P_{\text{theor}} - P_{\text{real}}$
  - Determination of **individual turbine icing times** (manually)




Evaluation period: 17.12.11-11.3.12


Turbine selection by commissioning date and minimum of 1800hrs availability



# MODELLED AND REAL ICING PERIODS COINCIDE WELL



**Significantly less icing induced power losses on AIS turbines**



**Season 2011/12, mean of references**



**CW 51- CW10**

Power production

1440 MWh

Power losses due to icing

695 MWh




**What happened in CW1 and CW3?**

**Improvement potential:**

CW1: icing condition

CW3: heating parameter settings



On average **560 MWh higher production with Anti-Icing Option** compared to reference turbines from CW51-CW10

## ➤ Performance analysis shows

- **Prevention of ice** on blades with Anti-Icing Option
- **Potentials for improvement** identified
- Significant **production gain** due to Anti-Icing Option



**Nordex provides turbines with an efficient Anti-Icing System**



# QUESTIONS?

## **Nordex Energy GmbH**

Langenhorner Chaussee 600, 22419 Hamburg, Deutschland

Telefon +49 40 30030 1000

Fax +49 40 30030 1101


E-Mail [info@nordex-online.com](mailto:info@nordex-online.com)



# Backup








## Improvement potential:

CW1: sensing of icing condition

CW3: heating parameter settings



Season 2011/12, mean of AIS turbines	CW 51- CW10
Power production	2000 MWh
Power losses due to icing	338 MWh