


# Potential and costs for wind power of providing system services to the electricity grid

**Salur Basbug & Anders Wickström**

Renewable Energy Systems

RISE Research Institutes of Sweden

financed by  
Swedish Energy  
Agency



# Anders Wickström

- Wind turbine design engineer at different private companies
- Independent consultant at Scandinavian Wind
- Researcher and project leader at RISE since 2018



Näsudden II på Gotland  
Diameter 80 m, 3 MW




ScanWind Demo I  
Nord Trönderlag  
Diameter 80 m, 2.5 MW



ScanWind SW3.5-90 Diameter  
90 m, 3.5 MW



GE Offshore-113 4.1 MW  
"Big Glenn"




Chalmers forskningsturbin  
på Björkö med trätorn


# Salur Basbug, PhD

▪ Research Institutes of Sweden, the unit "Renewable Energy Systems" →


- Aero-elastic wind turbine and windfarm simulations
- CFD & turbine control simulations






▪ Aker Solutions, *Offshore Oil & Gas (2018 – 2020)* →



▪ PhD at Imperial College London, *Turbulent Mixing (2013 – 2017)*




▪ MSc thesis at Airbus, *Combustion in Rocket Engines*




# Technical requirements for Fast Frequency Reserve defined by ENTSO-E

= European Network of  
Transmission System Operators  
for Electricity


- When the demand on the power exceeds the supply, AC grid frequency drops below 50 Hz
- The inertia of synchronized turbines and a range of system services support the grid stability
- FFR is required for a quick boost in power, until other (slower) support systems kick in.
- Wind turbines are perfect for FFR support if the control logic is set accordingly



## Synchronous grid areas of Europe



# Instantaneous minimum grid frequency simulated by ENTSO-E



- Many scenarios are simulated to see power grid's reaction if **1.45 GW** of supply is instantly lost
- A kinetic energy of 100 GWs is assumed to be the lowest value in the Nordic system (inertia of hydro turbines etc.)
- Equal amount of Frequency Containment Reserve (FCR-D) activated (50% in 5s, 100% in 30s)
- Our project assumes, FFR is activated at **49.5 Hz**, within **0.7s**
- That would require ca. 270 MW FFR, to maintain min. 49 Hz
- If 1500 turbine participate => in average **180 kW / turbine** sufficient
- 4000+ turbines already installed in Sweden
- FFR is booked & paid by *Svenska Kraftnät* (regardless of activation)

Figure 3: Simulation results of different FFR activation options, for an inertia level of 100 GWs, compared to 1) the reduction of reference incident (1450 MW) and 2) additional FCR-D volume of typical performance and stability settings.

# Energy storage by wind turbine inertia



- A rotating wind turbine has a certain amount of energy (E) stored in the inertia (J) of the turbine.
- This energy storage is depending on the angular velocity ( $\omega$ ).
- By decreasing the angular velocity, i.e., the rotor speed, this energy can be transformed into mechanical power (P).

$$E = \frac{1}{2} J \omega^2$$

$$\frac{\delta E}{\delta t} = J \omega \frac{\delta \omega}{\delta t} \Rightarrow P_{FFR}$$

## Stored energy from wind turbine rotational inertia

|                              |                |                  |
|------------------------------|----------------|------------------|
| Total number of turbines     | 4120           |                  |
| Total capacity               | 9061           | MW               |
| Average capacity             | 2.2            | MW               |
| Average turbine inertia      | 1.0E+07        | kgm <sup>2</sup> |
| Average angular velocity     | 1.0            | rad/s            |
| Average rotating energy      | 5.0E+06        | J                |
| <b>Total rotating energy</b> | <b>2.1E+10</b> | <b>J</b>         |

- This is almost 10 % of the existing inertia in Sweden.
- However, it is not connected to the grid by “stiff” synchronous generators.
- Turbine control is needed to utilize it.

# IEA 3.4 – 130 wind turbine model in FAST and VIDYN

- Within the project, we have created a model of the public IEA 3.4 MW – 130 m wind turbine in the aeroelastic codes OpenFAST and VIDYN
- The turbine control is based on the NREL DISCON concept.

## IEA Wind Task 37 on Systems Engineering in Wind Energy WP2.1 Reference Wind Turbines

Pietro Bortolotti<sup>1</sup>, Helena Canet Tarrés<sup>2</sup>, Katherine Dykes<sup>1</sup>, Karl Merz<sup>3</sup>, Latha Sethuraman<sup>1</sup>, David Verelst<sup>4</sup>, and Frederik Zahle<sup>4</sup>

<sup>1</sup>National Renewable Energy Laboratory, Golden CO, USA

<sup>2</sup>Wind Energy Institute, Technische Universität München, Germany

<sup>3</sup>SINTEF Energy Research AS, Trondheim, Norway

<sup>4</sup>Wind Energy Department, Technical University of Denmark, Roskilde, Denmark

May 23, 2019

### Abstract

This report describes two wind turbine models developed within the second work package (WP2) of IEA Wind Task 37 on Wind Energy Systems Engineering: Integrated RD&D. The wind turbine models can be used as references for future research projects on wind energy, representing a modern land-based wind turbine and a latest generation offshore wind turbine. The land-based design is a class IIIA geared configuration with a rated electrical power of 3.4-MW, a rotor diameter of 130 m, and a hub height of 110 m. The offshore design is a class IA configuration with a rated electrical power of 10.0 MW, a rotor diameter of 198 m, and a hub height of 119 m. The offshore turbine employs a direct-drive generator.

## 4 3.4-MW Land-Based Wind Turbine

**Cp-Max** was the tool mostly used in the development activities of the land-based wind turbine. Here, the design work aimed at developing a class 3A land-based wind turbine model with a rated electrical power of 3.37 MW, a rated aerodynamic power of 3.6 MW, a rotor diameter of 130 m and a hub height of 110 m. These values were selected by the project partners with the expectation that they will establish as standards within the land-based wind energy market. The optimization was run for minimum COE, estimated by a cost model developed at NREL [29].

### 4.1 Design Process

The wind turbine was designed against a set of critical design load cases (DLCs), selected to be run within the structural optimization loop of **Cp-Max**, including standard operating conditions in normal turbulence (1.1), operation under extreme turbulence (1.3), shut down cases in turbulent wind (2.1), and steady wind with gusts (2.3), as well as storm conditions (6.1, 6.2, 6.3) [17]. DLC 1.1 and DLC 1.3 were realized with three turbulent seeds, while the others with one, for a total of 151 dynamic simulations.

The aerodynamic design included 24 optimization variables describing twist at eight stations, chord at nine stations, and the position of the seven airfoils along blade span. The structural design was based on 50 variables parameterizing the skin, the two spar caps, the two webs, and the leading-edge (LE) and trailing-edge (TE) reinforcements at nine stations along blade span, as well as the diameter and wall thickness of ten tower sectors. In this reference design, the mechanical properties of the composites were kept fixed, while sweep curvature, angles in the composite fibers, and offset in the spar cap positions were all set to zero. After a total computational time of approximately 100 hours running on a workstation equipped with 56 logical processors, **Cp-Max** converged to the solution that is presented here.

The main wind turbine characteristics are summarized in Table 2. Notably, the table reports the values of initial capital cost (ICC) and COE that drove the optimization. The next section presents all the details of the design in terms of rotor aerodynamics, rotor structure, hub, drivetrain, nacelle, tower, and controller.

Table 2: Summary of the configuration of the land-based wind turbine.

| Data                    | Value       | Data                   | Value        |
|-------------------------|-------------|------------------------|--------------|
| Wind class              | IEC 3A      | Rated electrical power | 3.37 MW      |
| Rated aerodynamic power | 3.60 MW     | DT & Gen. efficiency   | 93.6%        |
| Hub height              | 110.0 m     | Rotor diameter         | 130.0 m      |
| Cut-in                  | 4 m/s       | Cut-out                | 25 m/s       |
| Rotor cone angle        | 3.0 deg     | Nacelle up tilt angle  | 5.0 deg      |
| Rotor solidity          | 4.09%       | Max $V_{tip}$          | 80.0 m/s     |
| Blade mass              | 16,441 kg   | Tower mass             | 553 ton      |
| Blade cost              | 120.9 k\$   | Tower cost             | 829.7 k\$    |
| Aerodynamic AEP         | 14.99 GWh   | Electrical AEP         | 13.94 GWh    |
| ICC                     | 4,142.1 k\$ | COE                    | 44.18 \$/MWh |

May 2019

IEA Wind TCP Task 37

Systems Engineering in  
Wind Energy - WP2.1  
Reference Wind Turbines

Technical Report




# Calculation of power curve for operation at optimal rotor speed

**Optimal rotor speed**, the corresponding power curve, and calculation of AEP

This is how the turbine is designed to operate, FFR-reserve = 0

| Input wind conditions |     |     |
|-----------------------|-----|-----|
| Average wind speed    | 7.5 | m/s |


| Summarized production IEA 3.4 - 130 |               |                   |
|-------------------------------------|---------------|-------------------|
| Turbine diameter                    | 130           | m                 |
| Air density                         | 1.225         | kg/m <sup>3</sup> |
| Rated power                         | 3.40          | MW                |
| Availability                        | 97%           |                   |
| Park loss factor                    | 95%           |                   |
| <b>Total production</b>             | <b>12.882</b> | <b>GWh/år</b>     |
| Capacity factor                     | 43.3%         |                   |





# Power curve for increased rotor speed

Increased rotor speed to have a FFR reserve of **100 kW**




| Input wind conditions |     |     |
|-----------------------|-----|-----|
| Average wind speed    | 7.5 | m/s |

| Summarized production IEA 3.4 - 130 |               |                   |
|-------------------------------------|---------------|-------------------|
| Turbine diameter                    | 130           | m                 |
| Air density                         | 1.225         | kg/m <sup>3</sup> |
| Rated power                         | 3.40          | MW                |
| Availability                        | 97%           |                   |
| Park loss factor                    | 95%           |                   |
| <b>Total production</b>             | <b>12.875</b> | <b>GWh/år</b>     |
| Capacity factor                     | 43.2%         |                   |

# Power curve for increased rotor speed

Increased rotor speed to have a FFR reserve of **200 kW**




| Input wind conditions |     |     |
|-----------------------|-----|-----|
| Average wind speed    | 7.5 | m/s |

| Summarized production IEA 3.4 - 130 |               |                   |
|-------------------------------------|---------------|-------------------|
| Turbine diameter                    | 130           | m                 |
| Air density                         | 1.225         | kg/m <sup>3</sup> |
| Rated power                         | 3.40          | MW                |
| Availability                        | 97%           |                   |
| Park loss factor                    | 95%           |                   |
| <b>Total production</b>             | <b>12.850</b> | <b>GWh/år</b>     |
| Capacity factor                     | 43.1%         |                   |

# Power curve for increased rotor speed

Increased rotor speed to have a FFR reserve of **300 kW**




| Input wind conditions |     |     |
|-----------------------|-----|-----|
| Average wind speed    | 7.5 | m/s |

| Summarized production IEA 3.4 - 130 |               |                   |
|-------------------------------------|---------------|-------------------|
| Turbine diameter                    | 130           | m                 |
| Air density                         | 1.225         | kg/m <sup>3</sup> |
| Rated power                         | 3.40          | MW                |
| Availability                        | 97%           |                   |
| Park loss factor                    | 95%           |                   |
| <b>Total production</b>             | <b>12.806</b> | <b>GWh/år</b>     |
| Capacity factor                     | 43.0%         |                   |

# Power curve for increased rotor speed

Increased rotor speed to have a FFR reserve of **400 kW**




| Input wind conditions |     |     |
|-----------------------|-----|-----|
| Average wind speed    | 7.5 | m/s |

| Summarized production IEA 3.4 - 130 |               |                   |
|-------------------------------------|---------------|-------------------|
| Turbine diameter                    | 130           | m                 |
| Air density                         | 1.225         | kg/m <sup>3</sup> |
| Rated power                         | 3.40          | MW                |
| Availability                        | 97%           |                   |
| Park loss factor                    | 95%           |                   |
| <b>Total production</b>             | <b>12.749</b> | <b>GWh/år</b>     |
| Capacity factor                     | 42.8%         |                   |

# Power curve for increased rotor speed

Increased rotor speed to have a FFR reserve of **500 kW**




| Input wind conditions |     |     |
|-----------------------|-----|-----|
| Average wind speed    | 7.5 | m/s |

| Summarized production IEA 3.4 - 130 |               |                   |
|-------------------------------------|---------------|-------------------|
| Turbine diameter                    | 130           | m                 |
| Air density                         | 1.225         | kg/m <sup>3</sup> |
| Rated power                         | 3.40          | MW                |
| Availability                        | 97%           |                   |
| Park loss factor                    | 95%           |                   |
| <b>Total production</b>             | <b>12.690</b> | <b>GWh/år</b>     |
| Capacity factor                     | 42.6%         |                   |

# Power curve comparison between optimal operation vs. high rotor speed

Comparison of AEP between operation at optimal rotor speed vs. operation with **400 kW** power reserve using high rotor speed



Power reserve via rotor speed ⇒ AEP is **99.0%** of optimal rotor speed

| Input wind conditions |     |     |
|-----------------------|-----|-----|
| Average wind speed    | 7.5 | m/s |

## Optimal operation

| Summarized production IEA 3.4 - 130 |               |                   |
|-------------------------------------|---------------|-------------------|
| Turbine diameter                    | 130           | m                 |
| Air density                         | 1.225         | kg/m <sup>3</sup> |
| Rated power                         | 3.40          | MW                |
| Availability                        | 97%           |                   |
| Park loss factor                    | 95%           |                   |
| <b>Total production</b>             | <b>12.882</b> | <b>GWh/år</b>     |
| Capacity factor                     | 43.3%         |                   |


## Power reserve of 400 kW rotor speed

| Summarized production IEA 3.4 - 130 |               |                   |
|-------------------------------------|---------------|-------------------|
| Turbine diameter                    | 130           | m                 |
| Air density                         | 1.225         | kg/m <sup>3</sup> |
| Rated power                         | 3.40          | MW                |
| Availability                        | 97%           |                   |
| Park loss factor                    | 95%           |                   |
| <b>Total production</b>             | <b>12.749</b> | <b>GWh/år</b>     |
| Capacity factor                     | 42.8%         |                   |

# Annual energy production depending on rotor speed concept

By plotting the actual and normalized AEP, the impact of the increased rotor speed is illustrated.


This is the cost to pay for to get the FFR reserve:



| Summary of reduced production caused by FFR capacity |           |                  |
|--|-----------|------------------|
| FFR [kW]   | AEP [GWh] | Relative AEP [%] |
| 0  | 12.882    | 100.0%           |
| 100  | 12.875    | 99.9%            |
| 200  | 12.850    | 99.8%            |
| 300  | 12.806    | 99.4%            |
| 400  | 12.749    | 99.0%            |
| 500  | 12.690    | 98.5%            |

# Power curve comparison between optimal operation vs. power curtailment

Comparison of AEP between operation at optimal power vs. operation with **400 kW** power reserve using power curtailment (lower rated power)



Power reserve via rating  $\Rightarrow$  AEP is **94.4 %** of optimal operation

| Input wind conditions |     |     |
|-----------------------|-----|-----|
| Average wind speed    | 7.5 | m/s |

## Optimal operation

| Summarized production IEA 3.4 - 130 |               |                   |
|-------------------------------------|---------------|-------------------|
| Turbine diameter                    | 130           | m                 |
| Air density                         | 1.225         | kg/m <sup>3</sup> |
| Rated power                         | 3.40          | MW                |
| Availability                        | 97%           |                   |
| Park loss factor                    | 95%           |                   |
| <b>Total production</b>             | <b>12.882</b> | <b>GWh/år</b>     |
| Capacity factor                     | 43.3%         |                   |

## Power reserve of 400 kW via curtailment



| Summarized production IEA 3.4 - 130 |               |                   |
|-------------------------------------|---------------|-------------------|
| Turbine diameter                    | 130           | m                 |
| Air density                         | 1.225         | kg/m <sup>3</sup> |
| Rated power                         | 3.00          | MW                |
| Availability                        | 97%           |                   |
| Park loss factor                    | 95%           |                   |
| <b>Total production</b>             | <b>12.166</b> | <b>GWh/år</b>     |
| Capacity factor                     | 46.3%         |                   |



# Example of FFR power reserve of 400 kW at mean wind speed 3 m/s


FFR capacity of 400 kW at 3 m/s, from 5.7 rpm to optimal 3.7 rpm

| Summary theoretical power reserve |            |                  |
|-----------------------------------|------------|------------------|
| Turbine inertia                   | 3.0E+07    | kgm <sup>2</sup> |
| Angular velocity at start         | 0.599      | rad/s            |
| Rotating energy at start          | 5.39E+06   | J                |
| Angular velocity at end           | 0.382      | rad/s            |
| Rotating energy at end            | 2.19E+06   | J                |
| Extracted energy                  | 3.20E+06   | J                |
| <b>FFR capacity</b>               | <b>407</b> | <b>kW</b>        |




# Example of FFR power reserve of 400 kW at mean wind speed 4 m/s

FFR capacity of 400 kW at 4 m/s, from 6.6 rpm to optimal 4.8 rpm




| Summary theoretical power reserve |            |                  |
|-----------------------------------|------------|------------------|
| Turbine inertia                   | 3.0E+07    | kgm <sup>2</sup> |
| Angular velocity at start         | 0.689      | rad/s            |
| Rotating energy at start          | 7.12E+06   | J                |
| Angular velocity at end           | 0.506      | rad/s            |
| Rotating energy at end            | 3.84E+06   | J                |
| Extracted energy                  | 3.28E+06   | J                |
| <b>FFR capacity</b>               | <b>417</b> | <b>kW</b>        |




# Example of FFR power reserve of 400 kW at mean wind speed 5 m/s

FFR capacity of 400 kW at 5 m/s, from 7.5 rpm to optimal 6.0 rpm




| Summary theoretical power reserve |            |                  |
|-----------------------------------|------------|------------------|
| Turbine inertia                   | 3.0E+07    | kgm <sup>2</sup> |
| Angular velocity at start         | 0.785      | rad/s            |
| Rotating energy at start          | 9.25E+06   | J                |
| Angular velocity at end           | 0.633      | rad/s            |
| Rotating energy at end            | 6.01E+06   | J                |
| Extracted energy                  | 3.23E+06   | J                |
| <b>FFR capacity</b>               | <b>412</b> | <b>kW</b>        |




# Example of FFR power reserve of 400 kW at mean wind speed 6 m/s

FFR capacity of 400 kW at 6 m/s, from 8.5 rpm to optimal 7.3 rpm




| Summary theoretical power reserve |            |                  |
|-----------------------------------|------------|------------------|
| Turbine inertia                   | 3.0E+07    | kgm <sup>2</sup> |
| Angular velocity at start         | 0.889      | rad/s            |
| Rotating energy at start          | 1.19E+07   | J                |
| Angular velocity at end           | 0.760      | rad/s            |
| Rotating energy at end            | 8.67E+06   | J                |
| Extracted energy                  | 3.18E+06   | J                |
| <b>FFR capacity</b>               | <b>405</b> | <b>kW</b>        |




# Example of FFR power reserve of 400 kW at mean wind speed 7 m/s

FFR capacity of 400 kW at 7 m/s, from 9.5 rpm to optimal 8.5 rpm




| Summary theoretical power reserve |            |                  |
|-----------------------------------|------------|------------------|
| Turbine inertia                   | 3.0E+07    | kgm <sup>2</sup> |
| Angular velocity at start         | 0.999      | rad/s            |
| Rotating energy at start          | 1.50E+07   | J                |
| Angular velocity at end           | 0.888      | rad/s            |
| Rotating energy at end            | 1.18E+07   | J                |
| Extracted energy                  | 3.15E+06   | J                |
| <b>FFR capacity</b>               | <b>402</b> | <b>kW</b>        |




# Example of FFR power reserve of 400 kW at mean wind speed 8 m/s

FFR capacity of 400 kW at 8 m/s, from 10.6 rpm to optimal 9.7 rpm




| Summary theoretical power reserve |            |                  |
|-----------------------------------|------------|------------------|
| Turbine inertia                   | 3.0E+07    | kgm <sup>2</sup> |
| Angular velocity at start         | 1.115      | rad/s            |
| Rotating energy at start          | 1.86E+07   | J                |
| Angular velocity at end           | 1.014      | rad/s            |
| Rotating energy at end            | 1.54E+07   | J                |
| Extracted energy                  | 3.20E+06   | J                |
| <b>FFR capacity</b>               | <b>408</b> | <b>kW</b>        |




# Example of FFR power reserve at mean wind speed 9 m/s

At 9 m/s, the FFR capacity is less than 400 kW if no power curtailment is implemented




| Summary theoretical power reserve |            |                  |
|-----------------------------------|------------|------------------|
| Turbine inertia                   | 3.0E+07    | kgm <sup>2</sup> |
| Angular velocity at start         | 1.191      | rad/s            |
| Rotating energy at start          | 2.13E+07   | J                |
| Angular velocity at end           | 1.137      | rad/s            |
| Rotating energy at end            | 1.94E+07   | J                |
| Extracted energy                  | 1.85E+06   | J                |
| <b>FFR capacity</b>               | <b>236</b> | <b>kW</b>        |



# No FFR power reserve at mean wind speed 10 m/s without curtailment


At 10+ m/s, there is no FFR capacity  
if no power curtailment is implemented as the rated rotor speed is reached.





# Correlation between wind speed distribution and FFR power reserve

FFR capacity plotted in a wind speed distribution graph




Annual average FFR reserve per turbine

$$\int_0^1 (\text{Power reserve}) \delta\phi = 240 \text{ kW}$$

An FFR capacity of 240 kW per turbine is enough for the worst-case scenario. The cost for this rapid reserve is a power production decreased of 1.0 %.


# Power and rotor speed during FFR 600 kW power boost

Results from aeroelastic simulations of the IEA 3.4 – 130 turbine for 6 minutes in turbulent wind




# Power and rotor speed during FFR 600 kW power boost

Results from aeroelastic simulations of the IEA 3.4 – 130 turbine for 6 minutes in turbulent wind




# Power and rotor speed during FFR 600 kW power boost

Results from aeroelastic simulations of the IEA 3.4 – 130 turbine for 6 minutes in turbulent wind




# Power and rotor speed during FFR 600 kW power boost

Results from aeroelastic simulations of the IEA 3.4 – 130 turbine for 6 minutes in turbulent wind




# Power and rotor speed during FFR 600 kW power boost

Results from aeroelastic simulations of the IEA 3.4 – 130 turbine for 6 minutes in turbulent wind




# Power and rotor speed during FFR 600 kW power boost

Results from aeroelastic simulations of the IEA 3.4 – 130 turbine for 6 minutes in turbulent wind



# Power and rotor speed during FFR 600 kW power boost


Results from aeroelastic simulations of the IEA 3.4 – 130 turbine for 6 minutes in turbulent wind






# Power and rotor speed during FFR 600 kW power boost

Results from aeroelastic simulations of the IEA 3.4 – 130 turbine for 6 minutes in turbulent wind




# Power and rotor speed during FFR 600 kW power boost

Results from aeroelastic simulations of the IEA 3.4 – 130 turbine for 6 minutes in turbulent wind




# Power and rotor speed during FFR 600 kW power boost

Results from aeroelastic simulations of the IEA 3.4 – 130 turbine for 6 minutes in turbulent wind




# Power and rotor speed during FFR 600 kW power boost

Results from aeroelastic simulations of the IEA 3.4 – 130 turbine for 6 minutes in turbulent wind



# Power and rotor speed during FFR 600 kW power boost

Results from aeroelastic simulations of the IEA 3.4 – 130 turbine for 6 minutes in turbulent wind



Using several scattered turbines, it is possible to keep the total wind power constant




## Key take-aways

- Fast Frequency Response (FFR) is required to maintain the balance in the power grid
  - Wind turbines can provide FFR with a minor change in the control system
  - The required energy can be stored in the kinetic energy of the rotor via an increased rpm
  - ...and released upon the drop in the grid AC frequency
  - The corresponding losses in efficiency is minimal (1% of AEP)
  - Installed wind capacity in Sweden is more than sufficient to provide the total need for FFR in Nordic grid
  - Next step: incorporation of the price signal into the control system (price of energy vs compensation for FFR)
- => Control logic decides how to maximize the revenue from that turbine

Thanks! Questions?


# Backup slide: Control System

LSS torque (Nm)



# Backup slide: Wind speed signal at mean wind speed 6 m/s

Results from generation of stochastic turbulent wind for 10 minutes




Looking at the mean value, the variations are significant smaller



# Backup slide: Power output in mean wind speed 6 m/s

Results from aeroelastic simulations of the IEA 3.4 – 130 turbine for 10 minutes in turbulent wind



# Backup slide: Power output in mean wind speed 6 m/s


Results from aeroelastic simulations of the IEA 3.4 – 130 turbine for 10 minutes in turbulent wind



It is not possible to run a turbine at constant power for longer times in low wind speeds

# Backup slide: Power output in mean wind speed 6 m/s

Results from aeroelastic simulations of the IEA 3.4 – 130 turbine for 10 minutes in turbulent wind




Using several scattered turbines, it is possible to keep turbine power relatively constant

# Backup slide: Annual energy production depending on power curtailment

By plotting the actual and normalized power production, the impact of the power curtailment is shown.


This is the cost to pay for to get the FFR reserve!



| Reduced production caused by curtailment |           |                  |
|--|-----------|------------------|
| Curtailment                              | AEP [GWh] | Relative AEP [%] |
| 0.00                                     | 12.716    | 100.00%          |
| 0.01                                     | 12.712    | 99.97%           |
| 0.11                                     | 12.564    | 98.81%           |
| 0.21                                     | 12.348    | 97.11%           |
| 0.31                                     | 12.121    | 95.33%           |
| 0.41                                     | 11.894    | 93.54%           |
| 0.51                                     | 11.667    | 91.76%           |

# Backup slide: Correlation between wind speed distribution and P\_rating

The calculated FFR capacity plotted in a wind speed distribution graph



| Summarized power reserve    |           |           |
|-----------------------------|-----------|-----------|
| Total wind power production | 20        | TWh       |
| Curtailment per turbine     | 500       | kW        |
| Production per turbine      | 11.67     | MWh       |
| Number of turbines          | 1573      |           |
| Production reduction        | 1.05      | MWh       |
| Production reduction        | 8.24      | %         |
| Average reserve per turbine | 56        | kW        |
| <b>Total power reserve</b>  | <b>88</b> | <b>MW</b> |



An FFR capacity of 56 kW per turbine is not enough for the worst-case scenario. The cost for this rapid reserve is a power production decreased of 8.2 %.

However, this power reserve might act for longer than 5 – 10 seconds



# Backup slide: Conclusion

Comparison of AEP between operation at optimal rotor speed vs. power reserve speed



FFR by rotor speed provides 5 times higher power reserve compared to curtailment.

The cost (AEP reduction) for FFR by rotor speed is only 1/6 compared to curtailment.

Power reserve by curtailment  $\Rightarrow$  92 % of AEP

Power reserve by rotor speed  $\Rightarrow$  99 % of AEP

